

The VDI/VDE metrological evaluation of range-based sensors with CENAGIS standard

Jakub Markiewicz¹, Sławomir Łapiński¹, Michał Kowalczyk¹, Mariusz Wiśniewski², Łukasz Ślusarski²

¹Warsaw University of Technology, Pl. Politechniki 1, 00-661 Warsaw, Poland

²Central Office of Measures, Ul. Elektoralna 2, 00-139 Warsaw, Poland

As part of the EU's ScanCloudT project, a team at Warsaw University of Technology (WUT) and Central Office of Measures (GUM) developed and modified VDI/VDE standard to assess the quality of surveying range-based sensors, and determined the measurement uncertainty and class of utilise device.

INTRODUCTION

Modern coordinate metrology faces growing demands for precision, speed, and automation, driven by advancements in measurement technologies and rising industrial quality standards. Optical measurement systems—such as structured light, photogrammetry, TOF sensors, CT, and MRI—require rigorous calibration and supervision, guided by international standards like ISO 9001 and ISO 10012-1. The German PTB's VDI/VDE 2634 [2] guidelines offer detailed procedures for verifying these systems, emphasizing the importance of calibration under real operating conditions. Key error types analyzed include probing error, sphere-spacing error, and flatness error, all critical for ensuring measurement reliability. However, for small measurement volumes (used in commonly defined surveying), such solutions do not exist. An attempt was made to apply and modify the VDI/VDE standard in the evaluation of the quality of surveying studies

METHODS AND PROCEDURES

The CENAGIS VDI/VDE allows for the verification of measuring systems based on a maximum measuring volume of 1.5 x 1.5 x 1 metres. The probing error reference: diameter – 47.638 mm, measurement uncertainty: 1.5 µm. The sphere space error reference: distance – 710.168 mm, measurement uncertainty: 6.0 µm. The flatness error reference: flatness error – 0.0528 mm, measurement uncertainty: 4.4 µm




Figure 1. The CENAGIS VDI/VDE benchmarks.




Figure 2. Spheres positions in probing error.

Figure 3. Scalebar position in sphere-spacing error.




Figure 4. Flatness benchmark.



Figure 5. Utilised sensors.

RESULTS




Figure 6. Probing error results.




Figure 7. Sphere-spacing error results.




Figure 8. Flatness results.

CONCLUSIONS

	Leica RTC 360	Z+F 5006h	Leica MS60	Mandeye
Probing error	Green	Yellow	Yellow	Red
Sphere space error	Green	Green	Green	Green
Flatness error	Green	Yellow	Yellow	Red
				Full compliance with the 1/5 relative error criterion
				Partly compliance with the 1/5 relative error criterion
				Exceeds 1/5 of the relative error value

contact: jakub.markiewicz@pw.edu.pl, mariusz.wisniewski@gum.gov.pl

FUNDING STATEMENT

The project 24DIT04 ScanCloudT has received funding from the European Partnership on Metrology, co-financed from the European Union's Horizon Europe Research and Innovation Programme and by the Participating States.